

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 2020-07-16-EX15258

**Report Reference** EX4141

**Issue Date** 2020-07-16

**Issued to:** American Avk Co.  
**Manufacturer Company:** 2155 Meridian Blvd.  
Minden, NV 89423-8601

Avk Polska Sp Zoo  
U1 Jakubowska 1  
62-045 Pniewy  
Poland

Saudi Valve Mfg. Co. Ltd.  
Industrial Area Phase 4  
Road 404, P. O. Box 10830  
Jeddah 21443  
Saudia Arabia

Avk International A/S  
Bizovvej 3  
8464 Galten  
Denmark

**Listed Company:** **AMERICAN AVK CO.**  
2155 Meridian Blvd.  
Minden, NV 89423-8601

**This is to certify that  
representative samples of**

## **Gate Valves**

See Addendum for Models


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 262 – Gate Valves for Fire-protection Service  
ULC/ORD-C262 – Gate Valves for Fire-Protection

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

Certificate Number 2020-07-16-EX15258  
Report Reference EX4141  
Issue Date 2020-07-16

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig(bar)
OS&Y	Series 25	2-1/2, 3, 4, 6, 8, 10, 12	Flanged, grooved, flanged by grooved, mechanical joint, push on	200 (14)
NRS*	Series 25	2-1/2, 3, 4, 6, 8, 10, 12	Flanged, grooved, flanged by grooved, mechanical joint, push on	200 (14)
NRS*	Series 45	14, 16	Flanged, mechanical joint, push-on, grooved end, tapping and Tyton	200 (14)
OS&Y	Series 45	2	Flanged, mechanical joint, push-on, tapping and Tyton	250 (17)
OS&Y	Series 45	2-1/2, 3, 4, 6, 8, 10, 12	Flanged, mechanical joint, push-on, grooved end, tapping and Tyton	250 (17)
OS&Y	Series 45	14, 16	Flanged, mechanical joint, push-on, tapping and Tyton	200 (14)
NRS*	Series 45	2-1/2, 3, 4, 6, 8, 10, 12	Flanged, mechanical joint, push-on, grooved end, tapping and Tyton	250 (17)
OS&Y	Series 55	18, 20, 24	Flanged, Flanged x Mechanical Joint, Mechanical Joint	200 (14)
NRS*	Series 55	18, 20, 24	Flanged, Flanged x Mechanical Joint, Mechanical Joint	200 (14)
OS&Y	Series 145	2-1/2, 3, 4, 6, 8	Flanged - Class 150	250 (17)
NRS*	Series 145	2-1/2, 3, 4, 6, 8	Flanged - Class 150	250 (17)

\* May be provided with indicator post mounting flange

End configurations shall be installed on systems not exceeding working capabilities of end configuration.

*B. Mahlen*

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

