



Certificate of Compliance

This certificate is issued for the following:

**Outside Screw and Yoke and Non-Rising Stem
Fire Service Water Control Valves**

Series 45

Sizes 2, 2-1/2, 3, 4, 6, 8, 10, 12, 14 and 16 inch NPS

Prepared for:

AVK Holding A/S Tech
Bizonvej 3 Skovby
8464 Galten,
Denmark

Manufactured at:

American AVK Co.
2155 Meridian Blvd.
Minden, NV 89423
United States

AVK Saudi Valves Manufacturing Co., Ltd
Phase 4, Street No. LO 404
Jeddah, KSA 21443

AVK Polska
ul Jakubowska 1
Pniewy, 62-045
Poland

FM Approvals Class: 1120/1130 – Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)

The Series 45 valves are FM Approved as of May 5, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
VP, Manager -Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group