



Certificate of Compliance

This certificate is issued for the following:

Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)

Series 45
OS&Y and NRS Type Gate Valves
Sizes 2, 2-1/2, 3, 4, 6, 8, 10, 12, 14 and 16 inch NPS, 250psi

Prepared for:

AVK Holding A/S
Bizonvej 3, Skovby
DK-8464 Galten, Denmark

Manufactured by:

American AVK Co.
2155 Meridian Blvd.
Minden, Nevada 89423
USA

AVK Saudi Valves Manufacturing Co. Ltd.
Phase 4, Street No. LO 404
Jeddah, Saudi Arabia 21443

AVK Polska
UI Jakubowska 1
Pniewy, 62-045
Poland

Approval Standard: FM 1120, 1130 (April 1997)

Approval Identification: PR464041
Revision Request: RR236812

Approval Granted: 05 December 2022
Authorized Date: 01 May 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

